



Ashville, Ohio

Founded 1882

Village of Ashville
P.O. Box 195
200 East Station Street
Ashville, OH 43103
Office: 740/983-6367 • Fax: 740/983-4703
Email: jwelsh@ashvilleohio.gov
Direct: 740/983-6367 • Cell: 740/207-1842



www.ashvilleohio.gov

Mayor
Charles K. Wise

Village Council
Nelson R. Embrey
President Pro Tempore
Roger L. Clark
Randy S. Loveless
R. David Rainey
Tracie N. Sorvillo
Darryl E. Ward

Clerk-Treasurer
April Grube

Planning & Zoning
Terry L. Moore, Chair
Jason J. Bartholow
Michael Peters
Adam Trimmer, Inspector
Darryl E. Ward
Charles K. Wise, Mayor

Chief of Service
Gregory Sturgill

Tax Administrator
Patricia S. Cavinee

Village Administrator
W. Franklin Christman

Personnel Director
Brian M. Garvine

Chief of Police
Jeffrey A. George

Chief of Wastewater
Adam P. Kehoe

Chief of Water
James R. Welsh

February 17, 2021

Water Conservation Advisory

FOR IMMEDIATE RELEASE TO RESIDENTS AND BUSINESS IN ASHVILLE

FOR IMMEDIATE RELEASE

Water Conservation Advisory

FOR MORE INFORMATION

Contact Jim Welsh or Franklin Christman

A water break has occurred on West Main Street between Cromley and Long Street. Repairs are underway but because of the age of valves and the temperature we have been unable to turn off the water to isolate the leak. That has caused a significant amount of water loss in our water-towers. We will need to recover the water that we have lost.

We are now issuing a "Conservation Advisory".

As a result of the loss of water we will need to conserve water. The village has 550,000 gallons in elevated storage and the past 12 months average daily flow has been 310,000 gallons. The Village only has 1½ days of storage. We do not want the distribution system to depressurize & have parts of town go dry. Therefore, we ask that residents decrease their use of water during this period. Water remains safe for now.

During this advisory no unnecessary use of water is permitted. Additional steps that the average person can take to help include:

- Taking shorter showers;
- Turning off the water when shaving or brushing teeth;
- Fixing leaky faucets or toilets;
- Delay or use only full loads when washing clothes or dishes;
- Using water-saving showerheads and faucets & toilets.

Discoloration Advisory

This event will result in discoloration. If discoloration occurs, let your water run until it clears. One word of caution: Rust will stain light colored laundry. Please be sure that both your cold and hot water are rust-free before you launder any whites. If such staining occurs, there is a remedy. Most grocery and hardware stores carry laundry aids, which remove rust stains. We have a Rust Stain Remover at the office called "Super Iron Out". If you happen to get this message late, come to 200 East Station if you need to remove iron stain from your clothing.

If there are any changes, you will be notified.

For more information, residents may contact their Water Department at (740) 983-6367 or (614)214-9223 or (740)207-1842. If there are any changes you will be notified in person or by our website, radio, TV, and Newspaper.

For more information, residents may contact their Water Department at (740) 983-6367.

Sincerely,

James Welsh

Jim Welsh, Chief of Water Operations

cc: Charles Wise, Mayor

There is the possibility of a boil alert if the repairs is not completed soon. You will be notified if that occurs.



"It is a place people will want to live, and businesses will want to locate."